



KEYED NOTES

- 1 LOCATE AIR VENT AND VACUUM BREAKER DOWNSTREAM OF CONTROL VALVE IN PIPING HIGH POINT.
- 2 INSTALL SWING JOINTS AT COIL CONNECTIONS.
- 3 LOCATE TEST TEE WITH 1/2" VALVE AND PLUG IN BOTTOM OF CONDENSATE LINE.

STEAM COIL PIPING DETAIL

(ON/OFF FLOW THROUGH PREHEAT COIL)

SCALE: NONE

NOTE:

- 1 SEE SHEET 3 FOR PNEUMATIC CONTROL DIAGRAM.
- 2 SEE SHEET 4 FOR DESIGN NOTES.

NO.	DATE	CLASS REV	REVISIONS	APP
FACILITY ENGINEERING MANUAL				
STEAM COIL PIPING				
ON/OFF FLOW THROUGH PREHEAT COIL				
APPROVED: DISCIPLINE POC DANNY NGUYEN			DATE: 6-28-99	
Los Alamos		Los Alamos National Laboratory Los Alamos, New Mexico 87545		2 OF 4
CLASSIFICATION: U		REVIEWER: DANNY NGUYEN		DATE:
REFERENCE DOCUMENT: CHAPTER 6		DRAWING NUMBER: ST6200		REV